



Product Service

Attestation of Compliance

No. E8N 10 01 63478 006

Holder of Certificate: Young Tech Co., Ltd.662-8, Pungmu-Dong
Kimpo-City, Keonggi-Do 415-070
REPUBLIC OF KOREA**Name of Object:** Smart Valve Positioner
Smart Positioner**Model(s):**

YT-2500abcdefgh

Note) for the suffix information in above model name;
- The "a" represents "L" or "R" according to the motion type.

- The "b" represents "S" or "D" according to acting type.
- The "c" represents "n" or "i" according to the explosion proof.
- The "d" represents 1 to 5 according to the lever type.
- The "e" represents 1 or 2 according to the connection type.
- The "f" represents 0 or 2 according to the ability of communication.
- The "g" represents 0 or 1 according to the existing of PTM.
- The "h" represents "F" or "S" according to the fail option.

Description of Object:Rated input current: (4-20) mA DC
Protection: IP66**Tested according to:**EN 61000-6-1:2007
EN 61000-6-2:2005
EN 61000-6-3:2007
EN 61000-6-4:2007

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: CPSC0102360**Date,** 2010-01-18

(Kang-Min Rhee)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1